

SUPPLEMENTARY TABLE S1. Ventilation detection on local exhausting devices at the thermometer facility in Jiangsu, 2019.

Division	Job/Location	Local exhausting	Wind velocity (m/s)		
			1	2	3
Trigonal thermometer	Distillation	Exhaust hood 1	0.02	0.03	0.02
		Exhaust hood 2	0.03	0.02	0.03
		Bulb machine	0.42	0.43	0.43
	Fill and degas	Degassing machine 1	0.17	0.18	0.17
		Degassing machine 2	0.13	0.14	0.12
	Contractor	Contractor machine	0.23	0.25	0.24
	Pull-Top	Pull-Top machine	0.20	0.21	0.22
Internal scaling thermometer	Sealing	Sealing machine 1	0.03	0.04	0.04
		Sealing machine 2	0.18	0.19	0.19